

TEST REPORT

No. : SZIN1605006995PS

Date : May 25, 2016

Page: 1 of 4

CUSTOMER NAME: FOSHAN VANCO BUILDING MATERIALS CO., LIMITED
ADDRESS: SHUNDE TECHNOLOGY & INNOVATION CENTER, GAOLI, RONGQI,
SHUNDE, FOSHAN, GUANGDONG, CHINA

The following sample(s) was/ were submitted and identified on behalf of the client as:

Sample Name : NON-COMBUSTIBLE ALUMINIUM COMPOSITE PANEL
SGS Ref. No. : GZIN1605022608MR
Date of Receipt : May 23, 2016
Testing Start Date : May 23, 2016
Testing End Date : May 25, 2016
Test result(s) : For further details, please refer to the following page(s)

Signed for
SGS-CSTC Standards Technical
Services Co., Ltd. Shenzhen Branch
Testing Center



Ramber Li
Authorized signatory



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services Co., Ltd.
Shenzhen Branch Materials Laboratory

SGS Bldg. No. 4, Jiangao Industrial Park, No. 430, Jihua Road, Bantian, Longgang District, Shenzhen, China 518129 t (86-755) 25328282 f (86-755) 83197625 www.ssgroup.com.cn
中国·深圳·龙岗区坂田吉华路430号江鹏工业园4栋SGS大楼 邮编: 518129 t (86-755) 25328282 f (86-755) 83197625 e sgs.china@sgs.com

TEST REPORT

No. : SZIN1605006995PS

Date : May 25, 2016


Page: 2 of 4

Summary of Results:

No.	Test Item	Test Method	Result	Conclusion
1	Climbing Drum Peel Strength	With reference to ASTM D1781-98(2012) and client's requirement	117 N·mm/mm	Pass

Note: Pass : Meet the requirements;
Fail : Does not meet the requirements;
/ : Not Apply to the judgment.

Original Sample Photo:



TEST REPORT

No. : SZIN1605006995PS

Date : May 25, 2016

Page: 3 of 4

Test Item: Climbing Drum Peel Strength

Sample Description: Panel

Test Method: With reference to ASTM D1781-98(2012) and client's requirement

Test Condition:

Specimen width: 25 mm

Testing speed: 25 mm/min

Lab Environmental Condition: 23±2℃, 50±5%RH


Test Result:

Test Item	Test Result	Client's requirement	Conclusion
Climbing Drum Peel Strength	117 N·mm/mm	≥100 N·mm/mm	Pass

Note:

1. Load required to overcome the resisting torque (F_0) was from test panel.
2. Test specimens were cut from the sample.
3. The surface with protected film was tested.
4. The above test was carried out by a SGS laboratory.

Test Photo:



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS Standards Technical Services Co., Ltd.
Shenzhen Branch

SGS Bldg. No. 4, Jianghao Industrial Park, No. 430, Jihua Road, Bantian, Longgang District, Shenzhen, China 518129
中国·深圳·龙岗区坂田吉华路430号江源工业园4栋SGS大楼 邮编: 518129


t (86-755) 25328282 f (86-755) 83197625 www.sgsgroup.com.cn
t (86-755) 25328282 f (86-755) 83197625 e sgs.china@sgs.com

TEST REPORT

No. : SZIN1605006995PS

Date : May 25, 2016

Page: 4 of 4



Equipment Information:

Equipment	Model	Equipment No.	Calibration date	Next Calibration date
Universal Testing Machine	CMT4304	GZMR-PL-E062	2015-11-18	2016-11-17

***** End of report *****